

CALIFORNIA DEPARTMENT OF FORESTRY & FIRE PROTECTION  
OFFICE OF THE STATE FIRE MARSHAL  
FIRE ENGINEERING - BUILDING MATERIALS LISTING PROGRAM

# LISTING SERVICE

**LISTING No.** 7320-0026:199 Page 1 of 1

**CATEGORY:** Speakers

**LISTEE:** Simplex Time Recorder Co., \*100 Simplex Dr., Westminster, MA 01441-0001  
Contact: Paul D. Mattern (978) 731-8542

**DESIGN:** Model 4902-9703 through 4902-9708 speakers. Refer to listee's data sheet for detailed product description and operational considerations.

**INSTALLATION:** In accordance with listee's printed installation instructions, applicable codes and ordinances and in a manner acceptable to the authority having jurisdiction.

**MARKING:** Listee's name, model number electrical rating and UL label.

**APPROVAL:** Listed as speakers. Input voltage for models 4902-9703, 9705 and \*9707 is 25 V rms and 4902-9704, 9706 and 9708 are 70 V rms. \*Models with a suffix of "H" are intended for indoor humidity of up to 95%. All versions are intended for indoor use only.

If this appliance is required to produce a distinctive three-pulse Temporal Pattern Fire Alarm Evacuation Signal (for total evacuation) in accordance with NFPA 72, 1993 Edition, the appliance must be used with a fire alarm control unit that can generate the temporal pattern signal. Refer to manufacturer's Installation Manual for details.

\*Rev. 06-21-2000



This listing is based upon technical data submitted by the applicant. CSFM Fire Engineering staff has reviewed the test results and/or other data but does not make an independent verification of any claims. This listing is not an endorsement or recommendation of the item listed. This listing should not be used to verify correct operational requirements or installation criteria. Refer to listee's data sheet, installation instructions and/or other suitable information sources.

Date Issued:

**JUNE 8, 2002**

*Listing Expires **June 30, 2003***

Authorized By:

**DIANE K. AREND**, Senior Deputy  
Program Manager